



COPY OF DOCUMENT

VALID ONLY WITH PROOF OF PURCHASE

322/759/454/2016

Gdańsk, 21st October 2016

HYGIENIC CERTIFICATE No 436/322/454/2016

1. **Product (material)** SWISS KRONO MDF
thickness 6 ÷ 40 mm
2. **Application** for furnishing and furniture manufacturing; according to Regulation of Minister of Health and Social Care dated on 12th March 1996 (Polish Monitor No 19, item 231) the product can be used in living quarters, places destined for permanent stay of the sick in health services' buildings and places destined for permanent stay of children and teenagers in educations' buildings, and also places destined for food storage – hereinafter referred as to the “places of A category”
and the product can be used in places destined for stay of people in public buildings different than classified as places of A category and in auxiliary quarters in apartments – hereinafter referred as to the “places of B category”
3. **Application institution** SWISS KRONO sp. z o.o.
ul. Serbska 56
68-200 Żary
4. **Manufacturer** SWISS KRONO sp. z o.o.
ul. Serbska 56
68-200 Żary
5. Evaluated positively as regards hygienic requirements on the following conditions
 - loading ratio 0,6 m²/m³ capacity of compartments in “places of A category”
 - loading ratio 1,2 m²/m³ capacity of compartments in “places of B category”
 The certificate does not concern working conditions and occupational hygiene during the assembly of product.
Places where the above mentioned product was applied should be ventilate.
6. Basis of certificate: application of OB-RPPD Sp. z o.o. BW/452/608/15 dated 18th June 2015, Test Report No 5352/58/2015 of 18th June 2015 issued by Research & Development Centre for Wood Based Panels in Czarna Woda, Kronopol sp. z o.o. dated 13th September 2016.
Hygienic class E-1.
7. The present certificate may be changed or voided if either party presents sufficient evidence. The document becomes invalid on 13-07-2020 or if any changes either in composition or manufacturing technology of the product have been introduced.

KIEROWNIK
Zakładu Toksykologii Środowiska
Lidia Wojska
prof. dr hab. Lidia Wojska